


Outdoor Unit

Models : HU121.U33, HU141.U33, HU161.U33

● Condenser Assembly Final Required Part


Level	Description	SVC Loc	Q'ty
...3	Condenser Assembly, Bending	554031	2
....5	Tube Assembly, Return Bending	352119	25
...3	Tube Assembly, Manifold (Outdoor)	552115	1
...3	Tube Assembly, Capillary	552111	1
...3	Tube Assembly, Connector	352111	2

● Condenser Assembly Final




Location No.	Description	Information	Etc.
263230D	Thermistor Assembly, NTC	SUC Temperature	CN_TH4
263230E	Thermistor Assembly, NTC	DIS Temperature	CN_TH5
263230F	Thermistor Assembly, NTC	Outdoor air Temperature	CN_TH7
263230G	Thermistor Assembly, NTC	MID-PIPE Temperature	CN_TH8
263230H	Thermistor Assembly, NTC	Condenser Temperature	CN_TH6

Panel, Front (Until June. 17, 2020)



Panel, Front (From June. 18, 2020)



Location No.	Description	Production date	
		Until Jun. 17, 2020	From Jun. 18, 2020
437211	Panel Assembly,Front(Outdoor)	AGL34578717	AGL34578717
237202	Panel,Front	MGC39426101	MGC66162501
349480	Orifice	4948A20011G	
435301	Grille,Discharge	MDX64291901	MDX64291901